



United States Department of the Interior  
BUREAU OF LAND MANAGEMENT  
FILLMORE FIELD OFFICE  
35 East 500 North  
Fillmore, Utah 84631



In Reply Refer to:  
3600  
(U-010)  
UTU-079455

June 2, 2004

CERTIFIED MAIL # 7003 2260 0005 6849 6680  
RETURN RECEIPT REQUESTED

DAVE PETERSON  
RESIDENT AGENT  
DELTA MINERALS INC  
545 S OAK DRIVE  
WOODLAND HILLS UT 84653

Dear Mr. Peterson:

On May 21, 2004, an inspection of your sales site was conducted, and it was noted that the valve on one of the diesel tanks had been opened, and that there was a large diesel spill on the ground. It was also noted that the overflow pit constructed for the tanks does not appear to be adequate. The overflow pit should be at least 150% of the capacity of the tanks.

In order to prevent future spills, within 30 days of receipt of this letter, please empty the tanks and into approved containers, and remove them from the site. Since the overflow pit is not adequate, and since you did not propose storing fuel in your current mine plan, the tanks should be removed as soon as possible, and the contaminated soil should be placed in the overflow liner to allow the fuel to decompose until such time as reclamation is conducted at the site. If you cannot remove the tanks within 30 days, please clean up the contaminated soil and dispose of it at an approved waste facility.

If you have any questions, please feel free to contact Sheri Wysong at (435) 743-3124.

Sincerely,

Sherry K. Hirst  
Field Office Manager

cc: Tom Munson, UDOGM (S/027/080)

RECEIVED

JUN - 7 2004

DIV. OF OIL, GAS & MINING